



Sub Divisional Level Water Quality Testing Laboratory
UTTARAKHAND JAL SANSTHAN
HALDWANI, NAINITAL

Name of the Customer/ Organization:	The Scholars Academy Kaladhungi Distt:- Nainital	Sample Description	The Scholars Academy Kaladhungi Distt:- Nainital
Type of Water (Surface water/Ground water)	Drinking-Water	Start of analysis End of analysis	29-07-26 30-07-26
Sample Code:	SDLWQTML/UJS/TSA-35	Sample collected By	Customer
Sample Receiving Date and Time:	29-07-26 / 2:30 PM	Date of Issue Report	30-07-26

Water Quality Test Report
Testing Details

S.N.	Parameters	Acceptable Limit (As per BIS 10500-2012)	Permissible Limit (in the Absence of alternative source) (As per BIS 10500- 2012)	Results
1	Colour (Hazen units)	5	15	1
2	Odour (Agreeable)	Agreeable	Agreeable	Agreeable
3	pH@25*c	6.5 to 8.5	No relaxation	7.12
4	Alkalinity as CaCO ₃ (mg/l)	200	600	167
5	Turbidity (NTU)	1	5	0.69
6	Total dissolved solid (mg/l)	500	2000	343
7	Chloride (mg/l)	250	1000	35.11
8	Total hardness (mg/l)	200	600	260
9	Calcium(as ca) (mg/l)	75	200	48
10	Magnesium (mg/l)	30	100	34.02
11	Total coliform (MPN/100ML)	ABSENT	ABSENT	ABSENT
12	E.Coli (MPN/100ML)	ABSENT	ABSENT	ABSENT

S. Singh
CHEMIST,
(Surendra Singh)
SDLWQTML,
UJS Haldwani (Nainital)

**Sub Divisional Level
Water Quality Testing & Monitoring Laboratory
UJS- Haldwani (Nainital)**

A. Singh
Technical Manager
In-Charge of Laboratory
UJS Haldwani (Nainital)

**TECHNICAL MANAGER
Sub- Divisional Level
Water Quality Testing
& Monitoring Laboratory
UJS- Haldwani (Nainital)**

